

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	SIR/03051/11/2023	Sample Details	Date & Time
Sample Classification:	Private	Collected By	,9466613500
Sender:	PM SHRI GSSS BARAGUDHA26550	Collection Date	25/11/2023 at 11:38
Location :-	, TAP WATER FROM PM SHRI GSSS BARAGUDHA, VPO BARAG	Received at lab	28/11/2023 at 11:38
Latitude :-	75.013082	Tested at Lab	04/12/2023
Longitude :-	29.694345		

Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in SIRSA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"




SANTOSH KUMARI, SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
ZONAL WATER TESTING LABORATORY SIRSA
email:-chemist.sirsa@phedharyana.gov.in

-----End of Report-----